

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2889

Dated : 08/07/2024

It is certified that an inspection team headed by Mr. Sujeeet Rai, Lab Technician from IDSP UNIT, Ghaziabad inspected the **ST. TERESA SCHOOL, SHAKTI KHAND 2 INDIRAPURAM GHAZIABAD** on 04/07/2024 and on the basis of Water Test Report bearing no. DSO/IDSP/2024/..... dt. 08/07/2024 of IDSP, Ghaziabad certified that the **ST. TERESA SCHOOL, SHAKTI KHAND 2 INDIRAPURAM GHAZIABAD** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by State Government. This certificate is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.

❖ Validity upto one year.



(Dr. R K Gupta)
District Public Health Expert
District Surveillance Unit
Ghaziabad
District Public Health Expert
District Ghaziabad

To
ST. TERESA SCHOOL,
SHAKTI KHAND 2 INDIRAPURAM
GHAZIABAD

Office of the Chief Medical Officer, Ghaziabad

Re.No. DSO/IDSP/2024/2889

Dated: 08/07/2024

WATER TEST REPORT

ADDRESS:- ST. TERESA SCHOOL, SHAKTI KHAND 2 INDIRAPURAM GHAZIABAD

PREVIOUS SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
N/A	N/A	N/A	N/A	N/A

NO of Sample collected : 01

PREVIOUS SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
04/07/2024	RO Water	Drinking	2911	Satisfactory

Test Result

H₂S Water test Kit : Negative (-V:) after 24-48hrs incubation

Comments:-

H₂S Water test Kit report – ve reflects that water is free from Coliforms Organism.

Recommendation:

Given Water is safe for Drinking Purpose.

- Validity upto one year.

Lab Technician
IDSP Lab
Ghaziabad


(Dr. Suruchi Saini)
Microbiologist IDSP Lab
Ghaziabad


(Dr. R.K Gupta)
District Public Health Expert
District Ghaziabad
District Public Health Expert
District Ghaziabad